

No:
331/2019

Station Officer,
Fire and Rescue station,
Kaduthuruthy,
Muttuchira P.O-686613
Dated:16.07.2019.
Phone :9497920285
Email.kdty.frs@kerala.gov.i

CERTIFICATE OF EXEMPTION FROM FIRE NON OBJECTION CERTIFICATE

The application for certificate for NOC submitted to this office by The Principal, Kendriya Vidhyalaya , Kaduthuruthy, Kottayam have verified the application on 03.07.2019 providing Fire Safety Certificate to Kendriya Vidhyalaya Kaduthuruthy . Velloore Panchayath, Vaikom Taluk, Kottayam District

The concerned Kendriya Vidya having ground floor only and which are less than 15 M height and 1000m2 respectively and found to be exempted from fire No Objection Certificate as per KMBR/KPBR vide Government Order F2.102/19Home dtd 02.04.2019, GO(P) No. 81/2017 LSGD dtd 31.10.2017, GO(P) No.82/2017/LSGD dtd31.10.2017 and F2.9400/2016 dtd 16.04.2019 Director General, Fire and Rescue Services, Thiruvananthapuram under the "Ease of doing Business" policy

Hence it is certified that the afforsaid building is exempted from acquiring NOC from Fire and Rescue Services Department as per the condition prescribed in the order cited above. Even though the fire system should be established as per the category of building mentioned and self attested fire system plan should be submitted by the applicant along with the certificate from architech/Engineer who prepared plan

And also certified that the above said building has been inspected by me as,per the instruction from The District Fire Officer, Fire and Resce Services, Kottayam and found 3 Nos ABC Extinghishers installed in the building and found correct



Shimoo
16/7/19

STATION OFFICER
FIRE AND RESCUE STATION
KADUTHURUTHY

[Signature]
प्राचार्य
Principal

केन्द्रीय विद्यालय, कडुत्तुरुत्ती
KENDRIYA VIDYALAYA KADUTHURUTHY
कोट्टयम KOTTAYAM - 686 613

